



January 12, 2015

Re: Mueller 2"-12" A2360 Resilient Wedge Gate Valves

MUELLER A2360 Series Resilient Wedge Gate Valves are manufactured and tested at the Mueller ISO 9001 registered facility in Chattanooga, Tennessee. Mueller A2360 valves are UL listed, FM approved, certified to ANSI/NSF 61, and meet or exceed all applicable requirements of ANSI/AWWA C509. Valves are built and tested in accordance with the requirements of the standards listed below.

Size	Model No.	AWWA C509 (PSI)	UL 262 (PSI)	FM 1120/1130 (PSI)	Hydro Shell (PSI)	Hydro Seat Test (PSI)
2"***	A2360	NA*	NA**	NA**	500	300
2-1/2"	A2360	NA*	200	200	500	300
3"-12"	A2360	250	200	200	500	300

*AWWA C509 does not recognize valves smaller than 3"

** 2" valves do not have a third party listing.

***2" valves have an operating pressure of 250 psi.

MUELLER CO.

Amanda Owens

1/12/15

Amanda Owens
Applications Engineer
Mueller Company
1401 Mueller Ave.
Chattanooga, TN 37406
aowens@muellercompany.com
(423) 495-1260

Date