



1401 Mueller Avenue  
 Chattanooga, TN 37406  
 (423) 698-8811 office  
 (423) 624-6784 fax

January 12, 2015

Re: Mueller 30"-54" A2361 Series Resilient Wedge Gate Vales (RWGV)

To Whom It May Concern:

**CERTIFICATE OF COMPLIANCE**

We hereby certify that Mueller Co. A2361 30"-54" RWGV's are manufactured and tested in the United States. Mueller valves are certified to ANSI/NSF 61 & 372 and meet or exceed all applicable requirements of AWWA C515. Valves are built and tested in accordance with the requirements of the standards listed below.

Size	Model No.	AWWA C515 (PSI)	Shell (PSI)	Seat Test (PSI)
30-48"	A2361	250	500	275
54"	A2361	250*	500	275

\*C515 does not address valves larger than 48"

MUELLER CO.

*Amanda Owens*

1/12/15

---

Amanda Owens  
 Applications Engineer  
 Mueller Company  
 1401 Mueller Ave.  
 Chattanooga, TN 37406  
[aowens@muellercompany.com](mailto:aowens@muellercompany.com)  
 (423) 495-1260

---

Date