



1401 Mueller Avenue
 Chattanooga, TN 37406
 (423) 698-8811 office
 (423) 624-6784 fax

January 12, 2015

Re: Mueller 4"-24" A2361 Series Resilient Wedge Gate Vales (RWGV)

To Whom It May Concern:

CERTIFICATE OF COMPLIANCE

We hereby certify that Mueller Co. A2361 4"-24" RWGV's are manufactured in the Mueller Co. ISO 9001 certified facility located in Chattanooga, TN. Mueller valves are UL Listed, FM Approved, certified to ANSI/NSF 61 & 372 and meet or exceed all applicable requirements of AWWA C515. Valves are built and tested in accordance with the requirements of the standards listed below.

Size	Model No.	AWWA C515 (PSI)	UL 262 (PSI)	FM 1120/1130 (PSI)	Shell (PSI)	Seat Test (PSI)
4-12"	A2361	350	350	350	700	525
14-16"	A2361	250	250	250	500	375
18-24"	A2361	250	175	N/A	500	275

MUELLER CO.

Amanda Owens

1/12/15

Amanda Owens
 Applications Engineer
 Mueller Company
 1401 Mueller Ave.
 Chattanooga, TN 37406
aowens@muellercompany.com
 (423) 495-1260

Date