



January 2015

MUELLER POST SUPER CENTURION 250 CERTIFICATE of CONFORMANCE

Mueller Company manufactures and assembles the A421 and A423 Super Centurion 250 fire hydrant in our ISO 9001 facility located in Albertville, Alabama.

The Super Centurion 250 is rated for 250 psi operating pressure, UL246 listed, FM 1510 approved, compliant with applicable requirements of AWWA C502 and certified to ANSI/ NSF 61 & 372. As such A421 and A423 hydrants are manufactured in accordance with the requirements of these standards including seat and shell pressure testing at two time rated pressure (500 psi).

MUELLER CO.

A handwritten signature in black ink that reads "Alan Channell". The signature is fluid and cursive, written over a white background.

Alan Channell
Product Manager
Water Products Division
Mueller Company
956 Industrial Blvd
Albertville, AL 35950
achannell@muellercompany.com
(256) 891- 6243

