



January 2015

MUELLER MONITOR HYDRANT CERTIFICATE of CONFORMANCE

Mueller Company manufactures and assembles the A479 Monitor Fire Hydrant in our ISO 9000 facility located in Albertville, Alabama.

The A479 is a 5-1/4" hydrant with an monitor elbow and ANSI 4" flange. The hydrant is rated for 250 psi operating pressure, is UL246 Listed, FM 1510 Approved, compliant with applicable requirements of AWWA C502 and is certified to ANSI/NSF 61 and 372. As such the A479 is manufactured in accordance the requirements of these standards including pressure testing at two times rated pressure (500 psi).

MUELLER CO.

A handwritten signature in black ink that reads "Alan Channell". The signature is fluid and cursive, with a large loop at the end of the last name.

Alan Channell
Product Manager
Water Products Division
Mueller Company
956 Industrial Blvd
Albertville, AL 35950
achannell@muellercompany.com
(256) 891- 6243