


1/2" - 2" GROUND KEY DESIGN CORPORATION VALVES



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: MUELLER Coupling thread 1-1/64" I.D. thru valve - for use with pito tube

H-9991N

3/4"	1"
------	----

See page 5.14 for installation tools



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: MUELLER Coupling thread (with coupling nut and leather washer) 1-1/64" I.D. thru valve - for use with pito tube

H-9995N

1"

See page 5.14 for installation tools



Ground Key Corporation Valve
Inlet: AWWA taper (MEULLER "CC") thread
Outlet: Inceasing I.P. thread (outlet is one size larger than inlet) 1-1/32" I.D. thru valve - for use with pito tube

H-9992N

1"


See page 5.14 for installation tools



Ground Key Corporation Valve
Inlet: Standard I.P. thread**
Outlet: M.I.P. thread

H-10012N

3/4"	1"	1-1/2" ‡	2" ‡
------	----	----------	------



Ground Key Corporation Valve
Inlet: AWWA taper (MEULLER "CC") thread
Outlet: Mueller coupling thread

H-10001N

1"

See page 5.14 for installation tools

** For use with Service Saddle only—cannot be machine inserted.

‡ Requires minimum ordering quantity. Contact MUELLER Customer Service Center for minimum order requirements and availability.

NOTE: Sizes shown above represent nominal size of inlet and outlet connections.

MUELLER Corporation Valves are manufactured and tested in accordance with ANSI/AWWA C800. Components in contact with potable water will also comply with latest requirements of the Federal Safe Drinking Water Act.