

1/2" - 2" GROUND KEY DESIGN CORPORATION VALVES



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: MUELLER® INSTA-TITE® Connection for CTS PE tubing*

H-15006N

3/4"	3/4"x1"‡	1"
------	----------	----



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: MUELLER® INSTA-TITE® Connection for CTS PE tubing*

H-15024N

3/4"	1"
------	----



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: MUELLER INSTA-TITE Connection for IPS PE pipe*

H-15005N

3/4"	3/4"x1"‡	1"
------	----------	----



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: MUELLER INSTA-TITE Connection for IPS PE pipe*

H-15026N

3/4"	1"
------	----



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: Copper flare straight connection

H-15000N

5/8"	1/2"‡	5/8" x 3/4"	3/4"	3/4" x 1"	1"
1-1/4"	1-1/2"	1-1/2"x2"	2"		



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: Copper flare straight connection

H-15025N

1/2"	3/4"	1"	1-1/4"	1-1/2"	2"
------	------	----	--------	--------	----



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: Copper flare eighth bend connection

H-15010N

3/4"	1"	1-1/2"	2"
------	----	--------	----



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: Copper flare eighth bend connection

H-15035N

3/4"‡	1"‡	1-1/2"	2"
-------	-----	--------	----



Ground Key Corporation Valve
Inlet: AWWA taper (MUELLER "CC") thread
Outlet: Copper flare quarter bend connection

H-15020N

5/8"x3/4"	3/4"	3/4"x1"	1"	1-1/2"	2"
-----------	------	---------	----	--------	----



Ground Key Corporation Valve
Inlet: AWWA I.P. thread
Outlet: Copper flare quarter bend connection

H-15045N

3/4"‡	1"	1-1/2"	2"
-------	----	--------	----

*See charts on pages 5.12-5.16 for tubing and pipe that may be used on these connections.

‡ Requires minimum ordering quantity. Contact MUELLER Customer Service Center for minimum order requirements and availability.

NOTE: Sizes shown above represent nominal size of inlet and outlet connections. When two sizes are given, the first is size of inlet and the second is size of outlet.

MUELLER Corporation Valves are manufactured and tested in accordance with ANSI/AWWA C800. Components in contact with potable water will also comply with latest requirements of the Federal Safe Drinking Water Act.