



January 29, 2015

Re: 2-1/2" – 12" R2365 OS&Y Resilient Wedge Gate Valves

WE HEREBY CERTIFY that the Mueller CO. R2365 Series OS&Y Resilient Wedge Gate Valves are manufactured and tested at the Mueller ISO 9001 registered facility in Chattanooga, Tennessee. Valves are UL listed, FM approved and certified to ANSI/NSF 61. Valves are built and tested in accordance with the requirements of the standards listed below.

Size	Model No.	UL 262 (PSI)	FM 1120/1130 (PSI)	Hydro Shell (PSI)	Hydro Seat Test (PSI)
2-1/2"-12"	R2365	250	250	500	375

MUELLER CO.

Amanda Owens

1/29/15

Amanda Owens
Applications Engineer
Mueller Company
1401 Mueller Ave.
Chattanooga, TN 37406
423-495-1260

Date