

<u>CERTIFICATE OF COMPLIANCE</u> Mueller A421/A423 Super Centurion Fire Hydrants

WE HEREBY CERTIFY that MUELLER CO. Super Centurion 250 Fire Hydrants are manufactured and tested at the Mueller ISO 9001 registered facility in Albertville, Alabama, USA. Mueller certifies these hydrants are UL 246 Listed, FM 1510 Approved, are certified to ANSI/NSF 61 & 372 and meet the requirements of AWWA C502. Production testing is performed in accordance with these standards and meets to the following specifications.

APPROVALS / PRODUCTION TESTING						
Size	Model No.	AWWA (psi)	UL (psi)	FM (psi) *	Hydro Shell (psi)	Hydro Seat Test (psi)
4-1/2" 5-1/4"	A421 A423	250	250	250	500	500

^{*} FM only approves open left hydrants

Mueller certifies that hydrant shoes, upper & lower barrels, bonnet and caps are manufactured in the Mueller foundry in Albertville per Mueller QA procedures; each heat is tested and certified to be within specification under a controlled program and in accordance with ASTM A126 Class B Gray Iron or ASTM A536 Ductile Iron as applicable.

All major castings (shoe, barrels, bonnet and caps) are primer coated with epoxy inside and out. Above ground exterior will be top coated with polyurethane enamel.

Sincerely,

Alan Channell Product Manager

Mueller Company, Water Products Division Website: www.muellercompany.com

January 2017

