

CERTIFICATE OF COMPLIANCE
Mueller A479 Super Centurion Monitor Fire Hydrant

WE HEREBY CERTIFY that MUELLER CO. A479 Super Centurion 250 Monitor Fire Hydrants are manufactured and tested at the Mueller ISO 9001 registered facility in Albertville, Alabama, USA. Mueller certifies these hydrants are UL 246 Listed, FM 1510 Approved, are certified to ANSI/NSF 61 & 372 and meet the requirements of AWWA C502. Production testing is performed in accordance with these standards and meets to the following specifications.

| APPROVALS / PRODUCTION TESTING | | | | | | |
|--------------------------------|-----------|------------|----------|-----------|-------------------|-----------------------|
| Size | Model No. | AWWA (psi) | UL (psi) | FM (psi)* | Hydro Shell (psi) | Hydro Seat Test (psi) |
| 5-1/4" | A479 | 250 | 250 | 250 | 500 | 500 |

* FM only approves open left hydrants

Mueller certifies that hydrant shoes, upper & lower barrels, bonnet and caps are manufactured per Mueller QA procedures; each heat is tested and certified to be within the specification shown in the chart under a controlled program and in accordance with ASTM A126 Class B Gray Iron or ASTM A536 Ductile Iron as applicable.

Shoe, lower barrel, bonnet and caps are primer coated with epoxy inside and out; upper barrels are e-coated. Above ground exterior will be top coated with polyurethane enamel.

Sincerely,


 Alan Channell
 Product Manager
 Mueller Company, Water Products Division
 956 Industrial Blvd., Albertville, AL 35950
 Website: www.muellercompany.com



January 2017