



# CERTIFICATE OF COMPLIANCE

## Mueller 3-12" 2361 Resilient Wedge Gate Valves

CHATTANOOGA PLANT

FEBRUARY 19, 2026

**WE HEREBY CERTIFY** that MUELLER CO. 3-12" A2361/T2361 Series RWGV's are manufactured and tested at the Mueller ISO 9001 registered facility in Chattanooga, TN, USA. Mueller certifies these valves are UL 262 Listed, FM 1120/1130 Approved, are certified to ANSI/NSF 61 and/or 372 and meet the requirements of AWWA C515. Production testing is performed in accordance with these standards and meets the following specifications.

APPROVALS / PRODUCTION TESTING						
Size	Model No.	AWWA (psi)	UL (psi)	FM (psi)	Hydro Seat Test (psi)	Hydro Shell Test (psi)
3-12"	A2361/T2361	350	350	350	525/525	700

\* NOTE: FM only approves Open Left valves.

Mueller certifies that the valve body, bonnet and wedge are manufactured in a Mueller foundry in Albertville, AL or Chattanooga, TN per Mueller QA procedures; each heat is tested and certified to be within specification under a controlled program and in accordance with ASTM A536.

Mueller certifies that manganese bronze stems are manufactured under a controlled program and are in accordance with ASTM B138.

Mueller certifies that the SBR rubber wedge material noted in the order above is manufactured under a controlled program and is in accordance with Mueller Rubber Specification R-88.

Mueller certifies that the Disc Nut meets ASTM B584 per AWWA C515.

Mueller certifies the coating supplied with these valves is Mueller® Pro-Gard™ Epoxy Coating, an exceptional fusion bonded epoxy electrostatically applied to valve internal and external surfaces to protect against corrosion. This coating is Sienna red in color, non-toxic and suitable for use with drinking water components. Mueller valves with Pro-Gard are certified to NSF 61 and meet or exceed AWWA C550 requirements. Valves have a standard coating of ten mils nominal thickness.

Mueller certifies that components for A2361/T2361 RWGV's are manufactured in accordance with Mueller Co. QA procedures which include but are not limited to relevant dimensional, visual, and functional inspection and verification.

Respectfully,

Matthew Littell  
Senior Product Manager  
Mueller Company  
1401 Mueller Avenue, Chattanooga, TN 37406  
Email: [mlittell@muellerwp.com](mailto:mlittell@muellerwp.com)  
Website: [www.muellercompany.com](http://www.muellercompany.com)