CERTIFICATE OF COMPLIANCE

Mueller 30”-54” 2361 Resilient Wedge Gate Valves

CHATTANOOGA PLANT FEBRUARY 19, 2026

WE HEREBY CERTIFY that MUELLER CO. 30”-54” A2361 Series RWGV’s are manufactured and tested at the Mueller ISO 9001 registered facility in Chattanooga, TN, or Calera, AL. Mueller certifies these valves are certified to ANSI/NSF 61 and/or 372 and meet the requirements of AWWA C515 and C550. Production testing is performed in accordance with these standards and meets the following specifications.

Size	Model No.	AWWA (psi)	Hydro Seat Test (psi)	Hydro Shell Test (psi)
30”-54”	A2361	250	275	500

Mueller certifies that the valve body, bonnet and wedge are manufactured in a Mueller approved foundry per Mueller QA procedures; each heat is tested and certified to be within specification under a controlled program and in accordance with ASTM A536 Ductile Iron.

Mueller certifies that manganese bronze stems are manufactured under a controlled program and are in accordance with ASTM B584.

Mueller certifies that valves wedges are encapsulated with EPDM rubber manufactured under acontrolled program and is in accordance with Mueller Rubber Specification R-97.

Mueller certifies that components for A2361 RWGV’s are manufactured in accordance with Mueller Co.QA procedures which include but are not limited to relevant dimensional, visual, and functional inspection andverification.

Respectfully,

Matthew Littell

Matthew Littell
Product Manager – Gate Valve Product Line
Mueller Company
1401 Mueller Avenue, Chattanooga, TN 37406
Email: mlittell@muellerwp.com
Website: www.muellercompany.com

**Visit www.muellerwaterproducts.com/global-brand-legal-disclaimer.*