

HYDRO-GUARD®

a MUELLER brand

HYDRO-GUARD® 300 SERIES WARM CLIMATE INGROUND PROGRAMMING Suggested Specifications

DIRECTED DISCHARGE DEVICE CONSTRUCTION - AUTOMATIC WATER DISTRIBUTION FLUSHING EQUIPMENT

1. GENERAL DESCRIPTION

- 1.1** The equipment furnished under this Section shall be automatic water distribution flushing equipment designed to be permanently or semi-permanently installed on water distribution lines in moderate to severe cold climates.
- 1.2** The primary purpose of this equipment shall be to automatically flush the desired amounts of water from water distribution systems for the purpose of improving and/or maintaining water quality.

2. PERFORMANCE

- 2.1** This equipment shall be installed completely below grade and protected above grade by an at-grade cast or composite 21-inch (21") lid.
- 2.2** The equipment shall be connected to a water distribution line as required by the plans or standard installation detail. The self-contained device is designed for automatic flushing of the water distribution line through the opening of a control valve that is an integral part of the device.
- 2.3** This equipment shall be capable of being programmed to activate up to 24 times daily on the days desired in one (1) minute to six (6) hours increments (on a continually rotating 7-day cycle or on an interval between every 1 to 30 days).
- 2.4** All programming shall be accomplished by means of a built-in programmable module. The built-in module shall be powered by a single 9-volt alkaline battery.
- 2.5** This equipment shall be capable of being programmed to activate up to 12 times daily on the days desired in one (1) minute to six (6) hour increments (on a continually rotating 7-day cycle or on an interval between every 1 to 30 days).

3. ACCEPTABLE MANUFACTURERS

- 3.1** Automatic water distribution flushing equipment to be supplied under this specification shall be Hydro-Guard® as manufactured by Mueller.
- 3.2** The automatic water distribution flushing system is comprised of the self-contained automatic flushing device with a sampling quick connect, freeze protection and an optional dechlorination system.

For more information about us or to view our full line of water products, please visit www.muellerwp.com or call Hydro-Guard customer service at: 1.800.423.1323.

Mueller refers to one or more of Mueller Water Products, Inc. a Delaware corporation ("MWP"), and its subsidiaries. MWP and each of its subsidiaries are legally separate and independent entities when providing products and services. MWP does not provide products or services to third parties. MWP and each of its subsidiaries are liable only for their own acts and omissions and not those of each other. MWP brands include Mueller®, Echologics®, Hydro Gate®, Hydro-Guard®, HYMAX®, Jones®, Krausz®, Mi.Net®, Milliken®, Pratt®, Pratt Industrial®, Singer®, and U.S. Pipe Valve & Hydrant. Please see muellerwp.com/brands and krauszusa.com to learn more.

© 2021 Mueller Water Products, Inc. All Rights Reserved. The trademarks, logos and service marks displayed in this document are the property of Mueller Water Products, Inc., its affiliates or other third parties. Products marked with a section symbol (§) are subject to patents or patent applications. For details, visit www.mwppat.com. These products are intended for use in potable water applications. Please contact your Mueller Sales or Customer Service Representative concerning any other application(s).

3.3 Programming for the 300 Series Warm Climate Flushing System shall be managed by way of a built-in programmer with a single 9-volt alkaline battery.

4. AUTOMATIC FLUSHING UNIT

4.1 Integral Piping and Control Valve – The piping and control valve components shall include the following:

- 4.1.1** Device must be certified by Underwriters Laboratories (UL) as meeting or exceeding the criteria of NSF-372.
- 4.1.2** The device's internal control valve shall be capable of being activated by a single 9-volt alkaline battery-operated controller.
- 4.1.3** The control valve shall be a globe valve type design capable of passing sand and other debris up to $\frac{5}{8}$ " in diameter without obstructing the valve's throat.
- 4.1.4** The device's standard internal piping shall be constructed of either Schedule 86 Pro or low-lead brass piping. A removable cartridge shall be incorporated into the design which shall allow the internals of the device to be raised and lowered within a protective ground sleeve. The internals of the device must be mounted on a steel plate that is protected from corrosion by a Rilsan Nylon coating or comparable coating.
- 4.1.5** The device's internal piping and control valve shall have an operational rating of 200 psi.
- 4.1.6** The control valve shall be constructed of a non-corrosive glass-reinforced nylon, or equal, and shall be fitted with stainless-steel hardware. The valve shall be of the type that can be easily rebuilt.
- 4.1.7** The valve shall include a single piece EPDM diaphragm.
- 4.1.8** The valve must be actuated by a 9-volt latching solenoid. Solenoid must be pressure rated between 0 - 10 bar (0 to 145.037738 psi). Wetted parts must be stainless-steel 400 or Polyamide. Leads must be 0.32 mm² x 80 cm².
- 4.1.9** The device shall feature an industry standard and approved, 2-inch, testable, double check valve for backflow prevention. The backflow prevention device must be constructed of low lead brass and a removable composite check valve body.
- 4.1.10** The device must provide a standard connection for a flow meter with a removable jumper bar installed for use where a meter is not to be installed and removable when a meter is to be utilized in the application.
- 4.1.11** The device must provide a dechlorination chamber that will accommodate a minimum of eight (8) dechlorination tablets for the adequate dechlorination of discharged water from the device.
- 4.1.12** The device shall be supplied with a standard 2-inch (2") male NPT water supply connection.

4.2 Housing

- 4.2.1** The components shall be protected from the environment and vandalism by a below-grade 33.5" x 24" x 24" DFW Meter Box and a composite lid that shall be mounted at grade on top of the below grade housing.
- 4.2.2** The self-contained device shall be supplied with a below-grade bottom-vented protective base that shall protect the internals of the flushing device; provide stability; and provide anti-buoyancy capabilities.
- 4.2.3** The below-grade base shall provide for an optional full debris shield that can be affixed to the bottom of the base.
- 4.2.4** The optional debris shield shall include a drain with filter fabric that must allow water to exit the base while preventing debris from entering the ground sleeve.

- 4.2.5** Load testing was performed in accordance with ASTM C 857, Standard Practice for Minimum Structural Design Loading for Underground Precast Concrete Utility Structures. The body/lid assembly was tested under AASHTO H2O loading for vertical load. The body and lid assembly was tested at ambient temperature conditions in an unrestrained condition. The load testing was conducted by Construction Testing Sciences (CTS).

4.3 System Sampling (Required) – The sampling system shall include the following features:

The device must be capable of being equipped with an optional, fully functional, sampling system that shall draw water quality samples from a point located between the utility water service line and the 2-inch (2") control valve of the flushing system. The sample collection point must be easily accessible from the top of the device. The sampling system shall include the following features:

- 4.3.1** The sampling system shall be constructed of polyethylene or other material with equal or greater resistance to bacterial regrowth and be connected with low lead brass or stainless-steel fittings.
- 4.3.2** The sampling system shall be designed in such a way to reduce the potential for contamination of the sampling system by allowing access and inspection of the internal piping compartment and components without disassembly or depressurization of the sampling system.
- 4.3.3** The sampling system shall draw water for water quality sampling from the inlet side of the 2-inch (2") adjustable control valve nearest to the service piping of the device. This positioning is essential in order to allow for a sample to be an accurate representation of the utility's water quality at the point of entry into the flushing device.
- 4.3.4** Connection to the device's sampling system shall be by means of a low lead or stainless-steel quick connection. The sampling tip shall be constructed from stainless-steel or low lead brass. The device's sampling connection shall be housed in a secure weather-tight area to minimize contamination of the sampling connection. The sampling connection itself shall be provided with a protective sanitary cover.

4.4 Electrical/Electronic System– The Electrical/Electronic System shall include the following features and capabilities:

- 4.4.1.1** Be capable of storing instructions via an integrated programmer and capable of operating the device's internal control valve. The controller shall be powered by a single 9-volt alkaline battery with the ability to install a secondary 9-volt alkaline battery for redundancy and extended life.
- 4.4.1.2** Offer a minimum of 12 flushing program events per day.
- 4.4.1.3** Be leap-year compatible, automatically accounting for February 29th every four years.
- 4.4.1.4** Incorporate LCD readout of clock and programming functions.
- 4.4.1.5** Offer manual on and off functions.
- 4.4.1.6** Be secured and water-resistant.
- 4.4.1.7** Have heavy-duty power cable.
- 4.4.2.1** All programming shall be accomplished by means of an integrated programmer module that is powered by a single 9-volt Lithium battery.
- 4.4.2.2** The system shall offer 24 flushing program events per day.
- 4.4.2.3** The system shall be leap-year compatible, automatically accounting for February 29th every four years.
- 4.4.2.4** Offer manual on and off functions.
- 4.4.2.5** Be secured and water-resistant.

- 4.4.2.6** Offer a percentage increase/decrease option that will allow the operator to make monthly adjustments by increasing or decreasing the flush durations by a percentage without the need to reset flush duration times.
- 4.4.2.7** Have heavy-duty power cable with an inferred connection that shall correspond with an inferred antenna on a programming module that shall be integrated into the flushing device.
- 4.4.3.1** Use an integrated 9-volt or greater latching solenoid to operate the control valve.
- 4.4.3.2** The solenoid must be able to be threaded directly into the 2-inch (2") adjustable control valve without the use of secondary adapters.

4.5 OEM Installed Dechlorination System (Required)

- 4.5.1** A tablet feed Dechlorination System shall be designed to accommodate 2 ⁵/₈th inch sodium sulfite or ascorbic acid tablets and it shall be installed inside of the device upon delivery.
- 4.5.2** A portion of the water being flushed shall be directed through the tablet feeder in the creation of a concentrated solution of the dechlorinating agent.
- 4.5.3** The directly treated, concentrated solution shall be introduced to the non-directly treated discharge on the device's splash plate resulting in a homogenous mixture effectively treating the entire discharge.

4.6 Execution

- 4.6.1** Prior to the installation, the drainage patterns for the intended installation location shall be viewed to ensure that any discharged water will not create hazardous conditions for pedestrian or vehicular traffic. The selected location's drainage pattern shall also permit discharged water to flow away from the automatic flushing device or be absorbed by the surrounding soil as prevent pooling.
- 4.6.2** Remove debris that might create uneven pressure on the device from the bottom of the hole. Compact the bottom of the hole to minimize settling after installation.
- 4.6.3** Install a 4-inch (4") lift of non-compacted sand or similar bedding material into the bottom of the hole.
- 4.6.4** Backfill the hole around the automatic flushing valve with clean fill, #57 stone and/or a combination of other appropriate materials.
- 4.6.5** Backfilling shall be accomplished in 6" lifts.
- 4.6.6** Use a level to ensure the device is level after each lift.
- 4.6.7** Ensure the lid is level.
- 4.6.8** The automatic flushing valve shall be disinfected in accordance with ADH and AWWA standards.